

Hose Lay 1	
# Needed	Supply Need
6	1.5" 100' Hose
6	1" 100' Hose
6	1" Nozzle
6	Sprinklers
12	1.5" Gated Wye
12	1.5"-1" Reducer
12	1"-3/4" Reducer
2	Mark III Pump Kit

Mark III pump with hose lay running south behind the rental cabins. Sprinklers set up at pump and at every 100' junction. 1" hose with nozzle connected and coiled at every 100' junction.

Drop Point One
All components for hose lay one and two. Surplus supplies


Hose Lay 2	
# Needed	Supply Need
30	1.5" 100' Hose
30	1" 100' Hose
30	1" Nozzle
30	Sprinklers
60	1.5" Gated Wye
60	1.5"-1" Reducer
30	1"-3/4" Reducer
1	2.5" Gate Valve
4	Mark III Pump Kit

Three Mark III pumps on the Firehole River with hose lay following the edge of the road around the rental cabins tying into the hydrant at the Southwest corner. Continuous hose lay with a sprinklers set up at each pump and at every 100' junction. 1" hose with nozzle connected and coiled at every 100' junction.

Source: Esri, Maxar, GeoEye, Earthstar Geographics, CNES/Airbus DS, USDA, USGS, AeroGRID, IGN, and the GIS User Community, Sources: Esri, Airbus DS, USGS, NGA, NASA, CIGAR, N Robinson, NCEAS, NLS, OS, NMA, Geodatasystem, Rijkswaterstaat, GSA, Geoland, FEMA, Intermap and the GIS user community.



Old Faithful Inn Cabins
Lone Star
WY-YNP-002006
September 4, 2020
Point Protection Plan



- Hydrants
- Drop Point
- Pump
- Firing Line
- Hose Lay
- Trails
- Building Polygons
- Accountable Property
- YELL Base Data
- 5' contour lines



A. Throop
9/3/2020 2319